

AIR CONDITIONER

Wall mounted type

SERVICE MANUAL

INDOOR



WHP09WMA21S WHP12WMA21S WHP18WMA21S WHP24WMA21S







WHP09SZA21S

WHP12SZA21S

WHP18SZA21S

OUTDOOR



WHP24SZA21S

(W), WESTINGHOUSE, and INNOVATION YOU CAN BE SURE OF are trademarks of Westing house Electric Corporation. Used under license by FUJITSU GENERAL AMERICA, INC. All Rights Reserved.

Notices:


- Product specifications and design are subject to change without notice for future improvement.
- For further details, please check with our authorized dealer.

Please Read Before Starting

This air conditioning system meets strict safety and operating standards. As the installer or service person, it is an important part of your job to install or service the system, so it operates safely and efficiently.

For safe installation and trouble-free operation, you must:

- · Carefully read this instruction booklet before beginning.
- Follow each installation or repair step exactly as shown.
- Observe all local, state, and national electrical codes.
- Pay close attention to all warning and caution notices given in this manual.





This symbol refers to a hazard or unsafe practice which can result in personal

injury or product or property damage.

If Necessary, Get Help

These instructions are all you need for most installation sites and maintenance conditions. If you require help for a special problem, contact our sales/service outlet or your certified dealer for additional instructions.

In Case of Improper Installation

The manufacturer shall in no way be responsible for improper installation or maintenance service, including failure to follow the instructions in this document.

SPECIAL PRECAUTIONS

WARNING

When Wiring

ELECTRICAL SHOCK CAN CAUSE SEVERE PERSONAL INJURY OR DEATH. ONLY A QUALIFIED, EXPERIENCED ELECTRICIAN SHOULD ATTEMPT TO WIRE THIS SYSTEM.

- Do not supply power to the unit until all wiring and tubing are completed or reconnected and checked.
- Highly dangerous electrical voltages are used in this system. Carefully refer to the wiring diagram
 and these instructions when wiring. Improper connections and inadequate grounding can cause
 accidental injury or death.
- Ground the unit following local electrical codes.
- Connect all wiring tightly. Loose wiring may cause overheating at connection points and a possible fire hazard.

When Transporting

Be careful when picking up and moving the indoor and outdoor units. Get a partner to help, and bend

your knees when lifting to reduce strain on your back. Sharp edges or thin aluminum fins on the air conditioner can cut your fingers.

When Installing

In a Ceiling or Wall

Make sure the ceiling/wall is strong enough to hold the unit's weight. It may be necessary to construct a strong wood or metal frame to provide added support.

In a Room

Properly insulate any tubing run inside a room to prevent "sweating" that can cause dripping and water damage to walls and floors.

• In Moist or Uneven Locations

Use a raised concrete pad or concrete blocks to provide a solid, level foundation for the outdoor unit. This prevents water damage and abnormal vibration.

• In an Area with High Winds

Securely anchor the outdoor unit down with bolts and a metal frame. Provide a suitable air baffle.

In a Snowy Area (for Heat Pump-type Systems)

Install the outdoor unit on a raised platform that is higher than drifting snow. Provide snow vents.

When Connecting Refrigerant Tubing

- \triangle Use the flare method for connecting tubing.
- \triangle Apply refrigerant lubricant to the matching surfaces of the flare and union tubes before connecting them, then tighten the nut with a torque wrench for a leak free connection.
- \triangle Check carefully for leaks before starting the test run.

When Servicing

- △ Turn the power OFF at the main power box (mains) before opening the unit to check or repair electrical parts and wiring.
- \triangle Keep your fingers and clothing away from any moving parts.
- \triangle Clean up the site after you finish, remembering to check that no metal scraps or bits of wiring have been left inside the unit being serviced.

Others



 \triangle Ventilate any enclosed areas when installing or testing the refrigeration system. Escaped refrigerant gas, on contact with fire or heat, can produce dangerously toxic gas.

 \triangle Confirm upon completing installation that no refrigerant gas is leaking. If escaped gas comes in contact with a stove, gas water heater, electric room heater or other heat source, it can produce dangerously toxic gas.

NOTE:

The figure, size and parameter of the product may not be identical with the service manual, please take the actual product as the standard.

Specifications

Туре					Wall mounted			
Туре					Inverter heat pump			
Model name					WHP09WMA21S	WHP12WMA21S		
Power supply					208/230 \			
Power supply intake	10				Outdo 198—			
Available voltage rang	je	1	T	kW	2.64	3.51		
Capacity			Rated	Btu/h	9,000	12,000		
		Cooling	Min May	kW	1.06—2.93	1.17—3.96		
			Min.—Max.	Btu/h	3,600—10,000	4,000—13,500		
Capacity			Rated	kW	2.78	3.81		
		Heating		Btu/h kW	9,500 1.05—3.07	13,000 1.17—4.10		
			Min.—Max.	Btu/h	3,600—10,500	4,000—14,000		
			Rated	Diam	0.655	0.920		
Input power		Cooling	Min.—Max.	kW	0.230—1.495	0.276—1.610		
Iliput power		Heating	Rated		0.720	1.110		
		_	Min.—Max.		0.230—1.495	0.276—1.610		
Current		Cooling Heating	Rated	Α	2.9 2.9	4.3 5.0		
				W/W	4.03	3.82		
EER		Cooling		Btu/hW	13.74	13.04		
COP		Heating		W/W	3.87	3.43		
		_		Btu/hW	13.19	11.71		
SEER HSPF		Cooling Heating		Btu/hW Btu/hW	22.5 10.7	22.0 10.5		
		Cooling			98	96		
Power factor		Heating		%	98	97		
Moisture removal				pints/h (L/h)	1.9 (0.9)	2.5 (1.2)		
Maximum operating c	urrent*1	Cooling		А	6.5	7.0		
Maximum operating o	I I	Heating	Turousp		6.5	7.0		
		Cooling	HIGHER HIGH		383 (650) 341 (580)	394 (670) 365 (620)		
			MED	CFM (m ³ /h)	294 (500)	312 (530)		
		Joseph Market	LOW		247 (420)	253 (430)		
	Airflow rate		LOWER		224 (
Fan	All llow rate		HIGHER		383 (650)	394 (670)		
		114:	HIGH		341 (580)	365 (620)		
		Heating	MED LOW		294 (500) 247 (420)	312 (530) 253 (430)		
			LOWER	-	224 (420)			
	Type × Q'ty	'			Crossflov			
	Motor output			W	2			
			HIGHER		4			
		Cooling	HIGH MED		3			
			LOW		29			
	.2		LOWER	-ID (A)	2			
Sound pressure level*	_		HIGHER	dB (A)	42			
		I I ti-	HIGH		3			
		Heating	MED LOW	-	3 2			
			LOWER	-	2			
		Dimensions (F		in (mm)	11-9/16 × 24-7/16 × 1-1/16			
		`	1 ·· vv ^ D)	in (mm)	(294 × 62	•		
Heat exchanger type		Fin pitch Rows × Stage	ie.	FPI	1 2 ×			
		Pipe type			Cop			
		Fin type			Alum	•		
Enclosure		Material			Polyst			
		Color			Wh			
Dimensions		Net			10-5/8 × 33-7 (270 × 85			
(H × W × D)		Gross		in (mm)	13-3/16 × 3			
					(335 × 94	10 × 265)		
Weight		Net Gross		lb (kg)	24 (11)	(9) 26 (12)		
			Liquid		24 (11) Ø 1/4 (1			
Connection pipe		Size	Gas	in (mm)	Ø 3/8 (I			
		Method	1	1	Fla	ire		
Drain hose		Material			PE/I			
		Tip diameter		in (mm)	Ø5/8 (Ø 15.4) (I.D.). 61 to 86 (
Operation range		Cooling		°F (°C) %RH	80 or			
		Heating		°F (°C)	61 to 86 (
Remote controller type	e	<u> </u>			Wireless (Wi			
NOTES								

- Specifications are based on the following conditions:
 Cooling: Indoor temperature of 80 °FDB (26.67 °CDB) /67 °FWB (19.44 °CWB), and outdoor temperature of 95 °FDB (35 °CDB) / 75 °FWB (23.9 °CWB).
 Heating: Indoor temperature of 70 °FDB (21.11 °CDB) /59 °FWB (15.56 °CWB), and outdoor temperature of 47 °FDB (8.33 °CDB) /43 °FWB (6.11 °CWB).
 Pipe length: 25 ft (7.5 m), Height difference: 0 ft (0 m). (Between outdoor unit and indoor unit.)
 Protective function might work when using it outside the operation range.
 *1: Maximum current is maximum value when operated within the operation range.

 * *2: Sound pressure level:

- Measured values in manufacturer's anechoic chamber.
- Because of the surrounding sound environment, the sound levels measured in actual installation conditions might be higher than the specified values here.

Туре					Wall mounted			
Туре					Inverter	neat pump		
Model name					WHP18WMA21S	WHP24WMA21S		
Power supply					208/230	V ~ 60 Hz		
Power supply intake						oor unit		
Available voltage range						-253 V		
			Rated	kW	5.28	6.86		
		Cooling		Btu/h kW	18,000 1.905—5.7153	23,400 2.345—7.767		
			Min.—Max.	Btu/h	6,500—19,500	8,000—26,500		
Capacity			+	kW	5.57	7.62		
			Rated	Btu/h	19,000	26,000		
		Heating	Min Man	kW	1.905—5.862	2.345—7.767		
			Min.—Max.	Btu/h	6,500—20,000	8,000—26,500		
		Cooling	Rated		1.385	1.870		
Input power			Min.—Max.	kW	0.345—2.760	0.414—2.990		
' '		Heating	Rated	_	1.638	2.500		
		Caaling	Min.—Max.		0.345—2.760 6.3	0.414—2.990 8.3		
Current		Cooling Heating	Rated	Α	7.2	11.1		
				W/W	3.81	3.67		
EER		Cooling		Btu/hW	13.00	12.51		
COD		Llastin		W/W	3.40	3.05		
COP		Heating		Btu/hW	11.60	10.40		
SEER		Cooling		Btu/hW	23.3	21.0		
HSPF		Heating		Btu/hW	11.6	10.5		
Power factor		Cooling		%	96	98		
		Heating			99	98		
Moisture removal		Caalina		pints/h (L/h)	3.2 (1.5) 12.0	5.1 (2.4) 13.0		
Maximum operating co	urrent*2	Cooling Heating		A	12.0	13.0		
	T	nealing	HIGHER		647 (1,100)	706 (1,200)		
	Airflow rate	Cooling	HIGH	1	589 (1,000)	647 (1,100)		
			MED	-	483 (820)	559 (950)		
			LOW		459 (780)	441 (750)		
			LOWER	0514 (3 //)	383 (650)	368 (625)		
Fan			HIGHER	CFM (m ³ /h)	647 (1,100)	706 (1,200)		
ran			HIGH		589 (1,000)	647 (1,100)		
		Heating	MED		483 (820)	559 (950)		
			LOW		459 (780)	441 (750)		
	T 011	LOWER			383 (650)	368 (625)		
	Type × Q'ty Motor output			l w	Crossflow fan × 1 35			
	INIOIOI Output	1	HIGHER	VV	48	50		
			HIGH	-	45	47		
		Cooling	MED	1	41	42		
		Gooming	LOW	1	37	36		
Sound pressure level*	.3		LOWER	dB (A)	34	33		
Souria pressure level			HIGHER]	48	50		
			HIGH	1	45	47		
		Heating	MED	4	41	42		
			LOWER	4	37	36		
			LOWER	-	34	33 -1/8 × 1-1/16		
		Dimensions (I	$H \times W \times D$)	in (mm)		-1/6 × 1-1/16 42 × 27.2)		
		Fin pitch		FPI	,	18		
Heat exchanger type		Rows × Stage	es			× 18		
		Pipe type				pper		
		Fin type			1	ninum		
Enclosure		Material				styrene		
		Color				hite		
Dimensions		Net				-1/2 × 9-5/16 130 × 237)		
(H × W × D)				in (mm)		5/8 × 12-7/16		
<u> </u>		Gross				210 × 316)		
Weight		Net		lb (kg)		14.5)		
TTOIGHT		Gross		ib (kg)		(17)		
		Size	Liquid	in (mm)	Ø 1/4 (Ø 6.35)	Ø 3/8 (Ø 9.52)		
Connection pipe			Gas	,	Ø 1/2 (Ø 12.70)	Ø 5/8 (Ø 15.88)		
		Method Material				are /PVC		
Drain hose		Tip diameter		in (mm)), Ø7/8 (Ø 23) (O.D.)		
				°F (°C)		(16 to 30)		
Operation range		Cooling		%RH	1	or less		
'		Heating		°F (°C)		(16 to 30)		
Remote controller type	Э					/ired [option])		
NOTES:					. `			

- Specifications are based on the following conditions:
 Cooling: Indoor temperature of 80 °FDB (26.67 °CDB) /67 °FWB (19.44 °CWB), and outdoor temperature of 95 °FDB (35 °CDB) / 75 °FWB (23.9 °CWB).
 Heating: Indoor temperature of 70 °FDB (21.11 °CDB) /59 °FWB (15.56 °CWB), and outdoor temperature of 47 °FDB (8.33 °CDB) /43 °FWB (6.11 °CWB).
- Pipe length: 25 ft (7.5 m), Height difference: 0 ft (0 m). (Between outdoor unit and indoor unit.)
- Protective function might work when using it outside the operation range. • *1: Maximum current is maximum value when operated within the operation range.
- *2: Sound pressure level:
- Measured values in manufacturer's anechoic chamber.
 Because of the surrounding sound environment, the sound levels measured in actual installation conditions might be higher than the specified values here.

Туре				Inverter heat pump			
Model name				WHP09SZA21S	WHP12SZA21S		
Power supply				208/230 V ~ 60 Hz			
Available voltage r	ange			198—253 V			
	Airflow rate		CFM (m ³ /h)	971 (1,650)	1,177 (2,000)		
Fan	Type × Q'ty		` '	Propeller fan × 1			
	Motor output		W	30)		
Sound pressure le	vel *1		dB (A)	53	3		
				26-7/8 × 18-3/16 × 11/16	33-1/16 × 21-1/2 × 11/16		
		Dimensions		(683 × 462 × 18.2)	(840 × 546 × 18.19)		
		(H × W × D)	in (mm)	25-3/4 × 18-3/16 × 11/16	33-1/16 × 21-1/2 × 11/16		
		,		(654 × 462 × 18.2)	(840 × 546 × 18.19)		
Heat exchanger ty	ре	Fin pitch	FPI	18	3		
		Rows × Stages		2 × 22	2 × 26		
		Pipe type		Сор	per		
		Fin type	Type (Material)	Aluminum			
		I iii type	Surface treatment	Blue fin			
Compressor	Туре			Rotary			
	'	Туре		R41	0A		
Refrigerant		Charge	lb oz	2 lb 2 oz	2 lb 9 oz		
		Charge	g	950	1,160		
Refrigerant oil		Туре		68HES-H	VG74 (POE)		
Enclosure		Material		Steel sheet			
Liiciosuic		Color		White			
	Net			19 × 28-1/8 × 9-7/16	23-1/16 × 31-7/8 × 11		
Dimensions	INCL		in (mm)	(482 × 715 × 240)	(585 × 810 × 280)		
(H × W × D)	Gross			20-7/8 × 33-11/16 × 13-3/8	25-3/16 × 37 × 15-3/16		
	Gloss			(530 × 830 × 340)	(640 × 940 × 385)		
Weight	Net		lb (kg)	60 (27)	73 (33)		
Weight	Gross		ib (kg)	65 (29.5)	79 (36)		
	Size	Liquid	in (mm)	Ø 1/4 (Ø			
		Gas	()	Ø 3/8 (Ø			
	Method			Fla			
Connection pipe	Pre-charge leng	th		24 (7	,		
	Max. length		ft (m)	65 (20)			
	Max. height diffe	arence	11 (111)	Indoor unit higher than outdoor unit: 32 (10)			
	Iviax. Height dille			Outdoor unit higher than indoor unit: 16 (5)			
Operation range		Cooling	°F (°C)	5 to 115 (-			
Operation range		Heating	1 (0)	-4 to 75 (-20 to 24)			


- Specifications are based on the following conditions:
 Cooling: Indoor temperature of 80 °FDB (26.67 °CDB) / 67 °FWB (19.44 °CWB), and outdoor temperature of 95 °FDB (35 °CDB) / 75 °FWB (23.9 °CWB).
 Heating: Indoor temperature of 70 °FDB (21.11 °CDB) / 59 °FWB (15 °CWB), and outdoor temperature of 47 °FDB (8.33 °CDB) / 43 °FWB (6.11 °CWB).
 - Pipe length: 24 ft 6 in (7.5 m), Height difference: 0 ft (0 m). (Between outdoor unit and indoor unit.)
- Protective function might work when using it outside the operation range.
- *1: Sound pressure level
- Measured values in manufacturer's anechoic chamber.
 Because of the surrounding sound environment, the sound levels measured in actual installation conditions might be higher than the specified values here.

Туре				Inverter heat pump			
Model name				WHP18SZA21S	WHP24SZA21S		
Power supply				208/230 V ~ 60 Hz			
Available voltage ra	inge			198—253 V			
F	Airflow rate		CFM (m ³ /h)	1,648 (2,800)	2,354 (4,000)		
Fan	Type × Q'ty			Propelle	rfan × 1		
	Motor output		W	60	70		
Sound pressure lev	el *1		dB (A)	55	58		
Dimensions (H × W × D)			in (mm)	35-1/4 × 24-13/16 × 11/16 (895 × 630 × 18.19) 34-1/8 × 24-13/16 × 11/16 (867 × 630 × 18.19)	35-1/4 × 24-13/16 × 11/16 (895 × 630 × 18.19) 34-1/8 × 24-13/16 × 11/16 (867 × 630 × 18.19) 19-11/16 × 24-13/16 × 11/16 (500 × 630 × 18.19)		
		Fin pitch	FPI	18			
		Rows × Stages		2 × 30	3 × 30		
		Pipe type		Copper			
		Type (Material)		Aluminum			
		Fin type	Surface treatment	Blue			
Compressor	Туре		1	Rot	arv		
Type		Type		R410A			
			lb oz	3 lb 7 oz	4 lb 12 oz		
•		Charge	g	1,550	2,150		
Refrigerant oil		Туре		VG74 (POE)			
Enclosure		Material		Steel sheet			
Enclosure		Color		White			
Dimensions	Net		in (mm)	25-9/16 × 33-7/8 × 12-3/16 (650 × 860 × 310)	31-5/16 × 34-13/16 × 14-7/16 (795 × 885 × 366)		
(H × W × D)	Gross		III (IIIIII)	28-3/8 × 39-3/16 × 16-9/16 (720 × 995 × 420)	35-1/16 × 41-5/16 × 19-11/16 (890 × 1,050 × 500)		
Weight	Net		lb (kg)	99 (45)	134 (61)		
**Cigiit	Gross		in (va)	108 (49)	144 (65.5)		
	Size	Liquid	in (mm)	Ø 1/4 (Ø 6.35)	Ø 3/8 (Ø 9.52)		
		Gas	()	Ø 1/2 (Ø 12.7)	Ø 5/8 (Ø 15.88)		
	Method			Fla			
Connection pipe	Pre-charge length		」	24 (
	Max. length		ft (m)	65 (/		
	Max. height differer	nce		Indoor unit higher than	` ,		
				Outdoor unit higher th			
Operation range		Cooling	°F (°C)	5 to 115 (
. 9		Heating	` ′	-4 to 75 (-20 to 24)			


- Specifications are based on the following conditions:
 Cooling: Indoor temperature of 80 °FDB (26.67 °CDB) / 67 °FWB (19.44 °CWB), and outdoor temperature of 95 °FDB (35 °CDB) / 75 °FWB (23.9 °CWB).
 Heating: Indoor temperature of 70 °FDB (21.11 °CDB) / 59 °FWB (15 °CWB), and outdoor temperature of 47 °FDB (8.33 °CDB) / 43 °FWB (6.11 °CWB).
 Pipe length: 24 ft 6 in (7.5 m), Height difference: 0 ft (0 m). (Between outdoor unit and indoor unit.)
- Protective function might work when using it outside the operation range.
- *1: Sound pressure level
- Measured values in manufacturer's anechoic chamber.
 Because of the surrounding sound environment, the sound levels measured in actual installation conditions might be higher than the specified values here.

Dimensions

Models: WHP09WMA21S and WHP12WMA21S




Models: WHP18WMA21S and WHP24WMA21S



Installation space requirement


Provide sufficient installation space for product safety.


Unit: in (mm)




Model: WHP09SZA21S


Unit: in (mm)









Model: WHP12SZA21S




Model: WHP18SZA21S


Unit: in (mm)





Model: WHP24SZA21S





Installation space

Models: WHP09SZA21S, WHP12SZA21S, WHP18SZA21S, and WHP24SZA21S


■ Space requirement

Provide sufficient installation space for product safety.

A CAUTION

Keep the space shown in the installation examples.

If the installation is not performed accordingly, it could cause a short circuit and result in a lack of operating performance.




Site for installing the indoor unit


- Where there is no obstruction near the air outlet and air can be easily blown to every corner.
- · Where piping and wall hole can be easily arranged.
- Keep the required space from the unit to the ceiling and wall according to the diagram on previous page.
- Where the air filter can be easily removed.
- Keep the unit and remote controller 3.28 ft (1 m) or more apart from television, radio etc.
- · Keep as far as possible from fluorescent lamps.
- Do not put anything near the air inlet to obstruct it from air absorption.
- Install on a wall that is strong enough to bear the weight of the unit
- Install in a place that will not increase operation noise and vibration.
- Keep away from direct sunlight and heating sources. Do not place flammable materials or combustion apparatuses on the top of the unit.

Site for installing the outdoor unit

- · Where it is convenient to install and well ventilated.
- Avoid installing it where flammable gas could leak.
- · Keep the required distance apart from the wall.
- Keep the outdoor unit away from greasy dirt, vulcanization gas exit.
- Avoid installing it by the roadside where there is a risk of muddy water.
- A fixed base where it is not subject to increased operation noise.
- Where there is not any blockage of the air outlet.
- Avoid installing under direct sunlight, in an aisle or sideway, or near heat sources and ventilation fans. Keep away from flammable materials, thick oil fog, and wet or uneven places.
- In case the pipe length is more than 24.6 ft (7.5 m), the refrigerant should be charged additionally, according to the table below.



Indoor unit is higher than outdoor unit




Outdoor unit is higher than indoor unit

Model	Required amount of additional refrigerant (oz/ft)
WHP09SZA21S	
WHP12SZA21S	0.215
WHP18SZA21S	
WHP24SZA21S	0.323

Refrigerant circuit


Models: WHP09SZA21S, WHP12SZA21S, WHP18SZA21S, and WHP24SZA21S



Air Purging and Leakage Test

- 1. Connect charging hose of manifold valve to charge end of low pressure valve (both high/low pressure valves must be tightly shut).
- 2. Connect joint of charging hose to vacuum pump.
- 3. Fully open the handle of Lo manifold valve.
- 4. Open the vacuum pump to evacuate. At the beginning, slightly loosen joint nut of low pressure valve to check if there is air coming inside. (If noise of vacuum pump has been changed, the reading of multimeter is 0) Then tighten the nut.
- 5. Keep evacuating for more than 15mins and make sure the reading of multi-meter is -1.0 X105 pa (-76cmHg).
- 6. Check the vacuum with the gage manifold valve, then close the gage manifold valve, and stop the vacuum pump.
- 7. Leave it for one or two minutes. Make sure the pointer of the gage manifold valve remains in the same position.
- 8. Remove the gage manifold valve quickly from the service port of the stop valve.

 After refrigerant pipes are connected and evacuated, fully open all stop valves on gas and liquid pipe sides.
- 9. Opening without fully opening lowers the performance and cause dangerous.
- 10. Tighten the cap to the service port to obtain the initial status.
- 11. Retighten the cap
- 12. Leak test



Test Running

\triangle Check after Installation


Items to be checked	Possible malfunction
Has it been fixed firmly?	The unit may drop, shake or emit noise.
Have you done the refrigerant leakage test?	It may cause insufficient cooling(heating)capacity
Is heat insulation sufficient?	It may cause condensation and dripping.
Is water drainage satisfactory?	It may cause condensation and dripping.
Is the voltage in accordance with the rated voltage marked on the nameplate?	It may cause electric malfunction or damage the product.
Is the electric wiring and piping connection installed correctly and securely?	It may cause electric malfunction or damage the part.
Has the unit been connected to a secure earth connection?	It may cause electrical leakage.
Is the power cord specified?	It may cause electric malfunction or damage the part.
Are the inlet and outlet openings blocked?	It may cause insufficient cooling(heating)capacity.
Is the length of connection pipes and refrigerant capacity been recorded?	The refrigerant capacity is not accurate.

\triangle Operation Test


- 1. Before Operation Test
- (1)Do not switch on power before installation is finished completely.
- (2)Electric wiring must be connected correctly and securely.
- (3)Cut-off valves of the connection pipes should be opened.
- (4)All the impurities such as scraps and thrums must be cleared from the unit.
- 2. Operation Test Method
- (1)Switch on power and press "ON/OFF" button on the remote controller to start the operation.
- (2)Press MODE button to select the COOL, HEAT (Cooling only unit is not available), FAN to check whether the operation is normal or not.

Wiring diagrams

Models: WHP09WMA21S, WHP12WMA21S, WHP18WMA21S, and WHP24WMA21S



Models: WHP09SZA21S, WHP12SZA21S, WHP18SZA21S, and WHP24SZA21S



Troubleshooting

Error Code Table

1.Indication on the outdoor unit:

When the unit has the following trouble and the compressor stops running, The LED of outdoor control board will show the error sequence automatically:

NOTE: ★:LIGHT O:FLASH ×:OFF

Error	Outdoor Failure Description	LED1	LED2	LED3	the root cause my be one of the following
	•	ts flash	every s	econd f	or the following faults
	Normal	×	×	×	
	Outdoor coil temperature sensor in trouble	*	×	*	 a. The outdoor coil sensor connect loose; b. The outdoor coil temperature sensor is failure; c. The outdoor control board is failure
	Compressor exhaust temperature sensor in trouble	*	×	×	 a. The compressor exhaust temperature sensor connect loose; b. The compressor exhaust temperature sensor is failure; c. The outdoor control board is failure
	Communication failure between the indoor unit and outdoor unit	×	×	0	 a. The communication cable connect loose; b. The communication cable is failure; c. The connection between the filter board and the outdoor control board is incorrect or loose; d. The connection between the filter board and the terminal is incorrect or loose; e. The indoor control board is failure; f. The PFC board is failure; g. The power board is failure; h. the outdoor control board is failure.
	Current overload protection	*	0	×	a. The fan motor run abnormally;b. The condenser or and evaporator is dirty;c. The air inlet and outlet is abnormally
	Maximum current protection	*	0	*	a. The outdoor control board is short circuit;b. The drive board is short circuit;c. The other components is short circuit
	Communication trouble between outdoor unit and driver	×	*	*	a. The connection wires connect looseb. The outdoor board or drive board is failure;

Outdoor EEPROM in trouble	*	*	*	a. The EEPROM chip is loose; b. The EEPROM chip inserted with opposite direction; c. The EEPROM chip is failure
Compressor exhaust temperature too high protection	×	0	*	a. The compressor exhaust temperature sensor is failure;b. The refrigerant of the unit is not enough
Outdoor ambient temperature sensor in trouble	*	*	×	 a. The outdoor ambient temperature sensor connect loose; b. The outdoor ambient temperature sensor is failure; c. The outdoor control board is failure
Compressor shell temperature too high protection	×	*	0	a. The compressor exhaust temperature sensor connect loose b. The refrigerant of the unit is not enough
Anti-freeze protection with cooling or overload protection with heating in indoor unit	×	0	0	 a. The indoor coil temperature sensor connect loose; b. The indoor coil temperature sensor is failure; c. The indoor control board is failure d. The refrigerant system is abnormal.
Compressor drive in trouble	0	×	0	a. The outdoor drive board is failure;b. The compressor is failurec. The outdoor control board is failure
Outdoor fan motor locked rotor protection	0	0	*	 a. The connection of the outdoor fan motor is loose; b. There are something block the outdoor fan; c. The fan motor is failure; d. The outdoor control board is failure
Outdoor coil anti-overload protection with cooling	×	*	×	 a. The refrigerant is too much; b. The outdoor fan motor is failure; c. The outdoor fan is broken; d. The condenser is dirty; e. The air inlet and air outlet of the indoor unit and the outdoor unit is not normally

IPM module protection	×	0	×	 a. The IPM board is failure; b. The outdoor fan is broken; c. The outdoor fan motor is failure; d. The outdoor fan has been blocked; e. The condenser is dirty; f. The outdoor unit has been installed without standard.
PFC protection	0	×	×	a. The PFC is failure; b. The outdoor drive board is failure
Compressor pre heating process	0	*	0	It is normal mode in cold weather
Chip in outdoor board in trouble	*	×	0	a. Using the wrong drive board;b. Using the wrong compressor.
AC voltage higher or lower protection	*	*	0	a. The supply voltage is higher or lower than normal;b. The inner supply voltage of the unit is higher or lower than normal
DC compressor start failure	0	0	×	a. The outdoor drive board is failure;b. The compressor is failure
Outdoor ambient temperature too low protection	*	0	0	a. Outdoor ambient temperature too low
Mark description: t	he light	s flash e	every tw	o seconds for the following faults
Protection against overheated outdoor radiator	О	×	×	a. Radiator sensors failb. Detection circuit of the sensor on the control panel fails
Protection of the system against too high pressure	0	0	×	 a. The pressure switch fails b. The pressure detection switch on the control panel fails c. The measured value of the system pressure exceeds the limit

When the compressor is in operation:

Mark	Mark description: ★ : LightO : Flash × : Off; the flash cycle is 1S						
No.	LED1	LED2	LED3	Reasons for the current operating frequency of the compressor is limited			
1	О	О	О	Normal frequency rising and decreasing, no limitation			
2	×	×	*	Frequency decreasing or prohibition of frequency rising caused by over-current			
3	×	*	*	Frequency decreasing or prohibition of frequency rising caused by anti-freezing of refrigeration or anti-oveload in heating			

4	*	×	*	Frequency dcreasing or prohibition of frequency rising caused by too high compressor discharge temperature
5				Limit to the max operating frequency caused by too low power voltage
6	*	*	*	Operation at fixed frequency (in the case of capability measuring or compulsory operation at fixed frequency)
7	О	×	×	Protective frequency decreasing against outdoor overload (overpower, over frequency converion rate, over torque, detection of DC under-voltage)
8	*	×	×	Frequency decreasing caused by indoor and outdoor communication fault
9	×	*	О	Frequency decreasing or prohibition of frequency rising protection against overload of outdoor coiled pipe
10	×	*	×	Frequency decreasing or prohibition of frequency rising for power-saving when it is being used simultaneously with other appliances

2.Indication by the indoor unit:

2.1. The 7-segment tube of the indoor display board will show the error code automatically when the unit has the following trouble:

Error	Power	Timer	Running	Sleep	Remark : ★Light	o Flas	h x OFF
code	1	2	3	4	Content	Remark	The root cause is may be one of the following
EA					The error code will display when the communication between display board and control board have in trouble		a. The connection between the display board and control board is loose;b. The indoor control board is failure.c. The wiring of the display board is failure.

2.2. When the unit has the following trouble and the compressor stops running, press the sleep button on the remote controller for 4 times in ten seconds and the 7-segment tube of the display board will show the error code as the following, if two malfunction happened at the same time, it need press the sleep button for 4 times again, the LED will show the other error code.

Refer to the remote controller which the sleep key can set into 4 different combination ways (Hisense's new design remote controller), when using to check the error codes only takes effect for pressing the sleep key 10 times in ten seconds instead of 4 times.

NOTE: If the troubleshooting inquiry display by 7-segment tube, then the error code will be displayed, otherwise only the LED of the display board can show.

Error	Running	Timer	Sleep	Power	Remark : ★Ligh	nt o Fla	sh x OFF
code	1	2	3	4	Content	Remark	The root cause is may be one of the following

T						
0					Normal	
1	х	О	x	х	The failure for temperature sensor of outdoor coil	 a. The outdoor temperature sensor loose; b. The outdoor temperature sensor is failure; c. The indoor control board is failure
2	×	О	*	×	Compressor exhaust temperature sensor in trouble	 a. The compressor exhaust temperature sensor connect loose; b. The compressor exhaust temperature sensor is failure; c. The outdoor control board is failure
5	*	О	×	×	IPM module protection	 a. The IPM board is failure; b. The outdoor fan is broken; c. The outdoor fan motor is failure; d. The outdoor fan has been blocked; e. The condenser is dirty; f. The outdoor unit has been installed without standard.
6	*	О	×	*	AC voltage higher or lower protection	 a. The supply voltage is higher or lower than normal; b. The inner supply voltage of the unit is higher or lower than normal
7	*	O	*	×	Communication failure between the indoor unit and outdoor unit	 a. The communication cable connect loose; b. The communication cable is failure; c. The connection between the filter board and the outdoor control board is incorrect or loose; d. The connection between the filter board and the terminal is incorrect or loose; e. The indoor control board is failure; f. The PFC board is failure; g. The power board is failure; h. The outdoor control board is failure.

					a. The fan motor run abnormally;
				Current	b. The condenser and
8 🖈	О	*	*	overload	evaporator is dirty;
				protection	c. The air inlet and outlet is
					abnormally
					a. The outdoor control board is short circuit;
				Maximum	b. The drive board is short
9 ×	×	О	×	current	circuit;
				protection	c. The other components is short
					circuit
				Communication	a. the connection wires connect
10				trouble	loose
10 ×	×	О	*	between outdoor unit	b. The outdoor board or drive
				and driver	board is failure;
					a. The EEPROM chip is loose;
11 ×	*	O	×	Outdoor EEPROM in	b. The EEPROM chip inserted
			_ ^	trouble	with opposite direction;
					c. The EEPROM chip is failure
				Outdoor	
12 ×	*	O	*	ambient temperature	Outdoor ambient temperature
^				too low	too low
				protection	
				Compressor	a. The compressor exhaust
				exhaust	temperature sensor is failure;
13 🖈	×	O	×	temperature	b. The refrigerant of the unit is
				too high protection	not enough
				ρισισσίωπ	a. The outdoor ambient
				Outdoor	temperature sensor connect
				ambient	loose;
14 🖈	×	О	*	temperature	b. The outdoor ambient
				sensor in	temperature sensor is failure;
				trouble	c. The outdoor control board is failure
				Compressor	a. The compressor exhaust
				shell	temperature sensor connect
15 ★	*	О	×	temperature	loose
				too high	b. The refrigerant of the unit is
				protection	not enough
				Anti-freeze	a. The indoor coil temperature
				protection with cooling or	sensor connect loose; b. The indoor coil temperature
16				overload	sensor is failure;
				protection with	c. The indoor control board is
				heating in	failure

						d. the refrigerant system is abnormal.
17					PFC protection	a. the PFC is failure;b. the outdoor drive board is failure
18					DC compressor start failure	a. the outdoor drive board is failure;b. the compressor is failure
19	×	×	×	О	Compressor drive in trouble	 a. the outdoor drive board is failure; b. the compressor is failure c. the outdoor control board is failure
20	*	×	×	0	Outdoor fan motor locked rotor protection	 a. the connection of the outdoor fan motor is loose; b. there are something block the outdoor fan; c. the fan motor is failure; d. the outdoor control board is failure
21					Outdoor coil anti-overload protection with cooling	 a. the refrigerant is too much; b. the outdoor fan motor is failure; c. the outdoor fan is broken; d. the condenser is dirty; e. the air inlet and air outlet of the indoor unit and the outdoor unit is not normally
22					Compressor pre heating process	it is normal mode in cold weather
24					Chip in outdoor board in trouble	a. Using the wrong drive board;b. Using the wrong compressor.
26					Overheated outdoor radiator	a. Radiator sensor failsb. Detection circuit of the sensor on the control panel fails
27					Protection against too high system pressure	 a. The pressure switch fails b. The pressure detection switch on the control panel fails c. The measured value of system pressure exceeds the limit

	1					
33	О	х	x	*	The failure for temperature sensor of indoor room	 a. The indoor room temperature sensor loose; b. The indoor room temperature sensor is failure; c. The indoor control board is failure.
34	О	х	*	х	The failure for temperature sensor of indoor coil temperature	 a. The indoor coil temperature sensor loose; b. The indoor coil temperature sensor is failure; c. The indoor control board is failure.
36	O	*	×	*	Communication failure between the indoor unit and outdoor unit	 a. the communication cable connect loose; b. the communication cable is failure; c. the connection between the filter board and the outdoor control board is incorrect or loose; d. the connection between the filter board and the terminal is incorrect or loose; e. the indoor control board is failure; f. the PFC board is failure; g. the power board is failure; h. the outdoor control board is failure.
38	О	*	*	*	Indoor EEPROM failure	a. The EEPROM chip loose;b. The indoor control board is failure
39	О	х	*	*	Indoor fan motor run abnormally	 a. There are something block the indoor fan motor; b. The fan motor cord connect loose; c. The fan motor is failure; d. The indoor control board is failure
41	*	*	О	*	The failure for Indoor grounding protective	The indoor control board is failure

2.2 LED display

Error	Sleep	Timer	Running	Remark : ★Ligh	t OFI	ash x OFF
code	1	2	3	Content	Remark	The root cause is may be one of the following

0				Normal	
1	0	*	*	The failure for temperature sensor of outdoor coil	 a. The outdoor temperature sensor loose; b. The outdoor temperature sensor is failure; c. The indoor control board is failure
2	0	*	х	Compressor exhaust temperature sensor in trouble	a. The compressor exhaust temperature sensor connect loose; b. The compressor exhaust temperature sensor is failure; c. The outdoor control board is failure
5	*	0	X	IPM module protection	 a. The IPM board is failure; b. The outdoor fan is broken; c. The outdoor fan motor is failure; d. The outdoor fan has been blocked; e. The condenser is dirty; f. The outdoor unit has been installed without standard.
6	x	О	х	AC voltage higher or lower protection	a. The supply voltage is higher or lower than normal;b. The inner supply voltage of the unit is higher or lower than normal
7	*	*	X	Communication failure between the indoor unit and outdoor unit	 a. The communication cable connect loose; b. The communication cable is failure; c. The connection between the filter board and the outdoor control board is incorrect or loose; d. The connection between the filter board and the terminal is incorrect or loose; e. The indoor control board is failure; f. The PFC board is failure; g. The power board is failure; h. The outdoor control board is failure.
8				Current overload protection	 a. The fan motor run abnormally; b. The condenser and evaporator is dirty; c. The air inlet and outlet is abnormally

9				Maximum current protection	 a. The outdoor control board is short circuit; b. The drive board is short circuit; c. The other components is short circuit
10	*	х	х	Communication trouble between outdoor unit and driver	 a. The connection wires connect loose b. The outdoor board or drive board is failure;
11	O	x	х	Outdoor EEPROM in trouble	a. The EEPROM chip is loose;b. The EEPROM chip inserted with opposite direction;c. The EEPROM chip is failure
12				Outdoor ambient temperature too low protection	Outdoor ambient temperature too low
13	О	х	*	Compressor exhaust temperature too high protection	a. The compressor exhaust temperature sensor is failure;b. The refrigerant of the unit is not enough
14	*	*	О	Outdoor ambient temperature sensor in trouble	 a. The outdoor ambient temperature sensor connect loose; b. The outdoor ambient temperature sensor is failure; c. The outdoor control board is failure
15	х	О	*	Compressor shell temperature too high protection	a. The compressor exhaust temperature sensor connect loose b. The refrigerant of the unit is not enough
16	*	х	*	Anti-freeze protection with cooling or overload protection with heating in	 a. The indoor coil temperature sensor connect loose; b. The indoor coil temperature sensor is failure; c. The indoor control board is failure d. The refrigerant system is abnormal.
17	x	*	x	PFC protection	a. The PFC is failure;b. The outdoor drive board is failure
18	х	*	*	DC compressor start failure	a. The outdoor drive board is failure;b. The compressor is failure

	1				
19	Х	*	О	Compressor drive in trouble	a. The outdoor drive board is failure;b. The compressor is failurec. The outdoor control board is failure
20	*	х	О	Outdoor fan motor locked rotor protection	 a. The connection of the outdoor fan motor is loose; b. There are something block the outdoor fan; c. The fan motor is failure; d. The outdoor control board is failure
21	х	х	О	Outdoor coil anti-overload protection with cooling	 a. The refrigerant is too much; b. The outdoor fan motor is failure; c. The outdoor fan is broken; d. The condenser is dirty; e. The air inlet and air outlet of the indoor unit and the outdoor unit is not normally
22				Compressor pre heating process	It is normal mode in cold weather
24				Chip in outdoor board in trouble	a. Using the wrong drive board;b. Using the wrong compressor.
26				Overheated outdoor radiator	a. Radiator sensor fails b. Detection circuit of the sensor on the control panel fails
27				Protection against too high system pressure	 a. The pressure switch fails b. The pressure detection switch on the control panel fails c. The measured value of system pressure exceeds the limit
33	*	0	О	The failure for temperature sensor of indoor room	 d. The indoor room temperature sensor loose; e. The indoor room temperature sensor is failure; f. The indoor control board is failure.
34	х	O	О	The failure for temperature sensor of indoor coil temperature	 d. The indoor coil temperature sensor loose; e. The indoor coil temperature sensor is failure; f. The indoor control board is failure.

36	O	*	O	Communication failure between the indoor unit and outdoor unit	 a. The communication cable connect loose; b. The communication cable is failure; c. The connection between the filter board and the outdoor control board is incorrect or loose; d. The connection between the filter board and the terminal is incorrect or loose; e. The indoor control board is failure; f. The PFC board is failure; g. The power board is failure; h. The outdoor control board is failure.
38	О	О	х	Indoor EEPROM failure	c. The EEPROM chip loose; d. The indoor control board is failure
39	0	O	*	Indoor fan motor run abnormally	 a. There are something block the indoor fan motor; b. The fan motor cord connect loose; c. The fan motor is failure; d. The indoor control board is failure
41	х	х	*	The failure for Indoor grounding protective	The indoor control board is failure

The failure is detected when the room temperature sensor broken or shorted over 5 sec.

The failure is detected when the temperature sensor of heater exchange broken or shorted over 5 sec.

The failure is detected when each setting data is not match after the EEPPOM self-check two times.

The failure is occur when the grounding signal is not detected after the appliance power ON.

Test the jumper terminals

Note:

When the whole machine is powered up, if the external unit does not work, to rule out the communications failures, adopt screening method such as short circuit on the jumper terminals to see if the external unit can be started normally or similar method.



There are two blue terminals on the outdoor control panel, as shown above.

Application: Short out the terminals, and power up the outdoor unit, then the outdoor unit may run independently. It can be determined that there is no internal and external communication faults.

When the environment temperature is lower than 18°C, you can't run the unit under the cool mode, but if you need run the unit at this moment ,such as add the gas or do more test, at this moment you can use this function,

Under this function, the outdoor motor and compressor will be forced to run until reaching a fixed frequency (general is 50~55Hz).

Trouble Diagnosis of Protection

Protection diagnosis of the complete machine (all types of protection during operation, i.e. under-voltage, over-voltage and overcurrent protection)

Note: List all types of protection that may occur to the complete machine and describe the conditions and signs of the start, course and end of such protection.

Voltage protection

Protection against AC input over-voltage/under-voltage

1. Conditions for protection against AC input over-voltage/under-voltage:

If the input AC voltage is greater than "protective over-voltage value" or less than "protective under-voltage value" for five seconds, over-voltage/under-voltage protection tarts.

2.Protection actions against AC input over-voltage/under-voltage

The system stops operation.

3. Conditions for ending AC input over-voltage/under-voltage:

If the input AC voltage is lower than "the protective over-voltage value" -10V, or higher than "the protective under-voltage value" +10V, the over-voltage/under-voltage protection will be released.

Current protection:

1.Protection against over-current

Conditions for over-current protection: if the current is equal to or greater than "current value for starting the refrigeration current protection (E2 value)" for six seconds, over-current protection starts.

Protection actions against over-current: indoor display screen and outdoor indicator give indications, the

compressor and outdoor fan stop, but indoor fan runs normally.

Condition for ending over-current protection: when the current drops below "current value for releasing the refrigeration current protection (E2 value)", over-current protection will be released.

2. Frequency decreasing for over-current

Conditions for over-current frequency decreasing : if the current is equal to or greater than "current value for starting the refrigeration current protective frequency decreasing (E2 value)", over-current frequency decreasing starts.

Over-current frequency decreasing actions: the compressor will decrease frequency at rate of (E2 value)Hz/S. The indoor and outdoor fans run.

Conditions for ending over-current frequency decreasing : when the current drops below "current value for starting the refrigeration current protective prohibition of frequency rising (E2 value)", over-current under-clocking will be released.

3. Prohibition of frequency increasing of compressor exhausting

Conditions for prohibition of frequency rising of compressor discharge

Condition 1: in the case of frequency decreasing of compressor discharge, the discharge temperature of the compressor drops below X4°C.

Condition 2: in normal operation, the discharge temperature of compressor reaches X5°C.

Either of the above two conditions is met, prohibition of frequency rising of compressor discharge begins.

Actions relates to prohibition of frequency rising of compressor discharge: the frequency of compressor maintains at the current level, which may decrease as the case requires while cannot rise. The indoor and outdoor fans run.

Condition for ending prohibition of frequency rising of compressor discharge: if the temperature of compressor discharge drops below X6°C, prohibition of frequency rising of compressor discharge will be released.

4. Prohibition of frequency for anti-overload of outdoor coiled pipe

Condition for anti-overload prohibition of frequency of outdoor coiled pipe: in the case of anti-overload frequency decreasing of outdoor coiled pipe, anti-overload prohibition of frequency of the unit begins when the temperature of outdoor coiled pipe drops below "the anti-overload frequency decreasing temperature of outdoor coiled pipe".

Actions relates to anti-overload prohibition of frequency of outdoor coiled pipe: the frequency of compressor maintains at the current level, which may decrease as the case requires while cannot rise. The indoor and outdoor fans run.

Condition for ending anti-overload prohibition of frequency of outdoor coiled pipe: if the temperature of outdoor coiled pipe drops below "temperature to release the anti-overload state of outdoor coiled pipe", anti-overload prohibition of frequency of outdoor coiled pipe will be released.

Trouble Diagnosis of Compressor

Judging the connecting terminals of inverter compressor:

It is impossible to identify terminals U, V and W of inverter compressor with multi-meter. Just connect the terminals in the same way as the original unit when replacing the compressor. A wrong connection will lead to reverse and loud noise of the compressor.

Resistance of compressor coil:

Measure the resistance between any two terminals, which are about a few Ohms, three phases having the same resistance.

Trouble Diagnosis of Electric Filter Board

Visual examination: as the circuit is simple, the connection may be checked visually to see whether any loose or poor connection.

Voltage test: the voltage at the input end shall be the same as the voltage at the output end.


Trouble Diagnosis of Electric Communication

Step one: to determine whether the connecting cables and tether cables of indoor/outdoor units are correctly wired. If not, change wiring order and test connection.

Step two: to determine whether there is loose connection.


Fasten the connection in the case of loose connection and then conduct verification.

Step three: measure the voltage between SI and N with multi-meter and see whether the voltage fluctuates between 0V and 24V. Please directly replace indoor and outdoor control boards if there are not voltage fluctuations.




INDOOR UNIT WHP09WMA21S

No.	Part number	Description	
1	1906600	Bracket wall	
2	1984201	Baffle	
3	1854439	Base assembly	
4	1555378	Vertical louver	
5	1555381	Holder center	
6	1555385	Holder center	
7	1555387	Holder center	
8	1260259	Step motor	
9	1555386	Guard motor	
10	1555374	Louver	
11	1466014	Cross flow fan assy	
12	1223739	Bearing	
13	1465670	Baffle	
14	1512275	Evaporator	
15	2091423	Guard motor	
16	1838324	DC motor	
17	2091436	Cover motor	
18	4151687	Remote control	
19	1840039	Cover wire	
20	1837499	Thermistor pipe	
21	1896665	Thermistor pipe	
22	1839902	Clamp cord	
23	1852126	Terminal	
24	1465763	Cover wire	
25	1465762	Electric box cover	
26	1994823	Controller PCB	
27	1868909	Electric box	
28	1465761	Electric box cover	
29	1470426	Drain hose	
30	1222824	Plug	
31	1468408	Step motor	
32	1555390	Ornamental part	
33	2007198	Front panel	
34	1555391	Ornamental part	
35	1874771	Display assembly	
36	4151756	Intake grille	
37	1826563	Ornamental part	
	1506312	Air filter	




INDOOR UNIT WHP12WMA21S

No.	Part number	Description	
1	1906600	Bracket wall	
2	1984201	Baffle	
3	1854439	Base assembly	
4	1555378	Vertical louver	
5	1555381	Holder center	
6	1555385	Holder center	
7	1555387	Holder center	
8	1260259	Step motor	
9	1555386	Guard motor	
10	1555374	Louver	
11	1466014	Cross flow fan assy	
12	1223739	Bearing	
13	1465670	Baffle	
14	1512275	Evaporator	
15	2091423	Guard motor	
16	1838324	DC motor	
17	2091436	Cover motor	
18	4151687	Remote control	
19	1840039	Cover wire	
20	1837499	Thermistor pipe	
21	1896665	Thermistor pipe	
22	1839902	Clamp cord	
23	1852126	Terminal	
24	1465763	Cover wire	
25	1465762	Electric box cover	
26	1994827	Controller PCB	
27	1868909	Electric box	
28	1465761	Electric box cover	
29	1470426	Drain hose	
30	1222824	Plug	
31	1468408	Step motor	
32	1555390	Ornamental part	
33	2007198	Front panel	
34	1555391	Ornamental part	
35	1874771	Display assembly	
36	4151756	Intake grille	
37	1826563	Ornamental part	
	1506312	Air filter	




INDOOR UNIT WHP18WMA21S

No.	Part number	Description	
1	1907022	Bracket wall	
2	1954365	Base assembly	
3	1260311	Step motor	
4	1541366	Holder center	
5	1541373	Guard motor	
6	1541456	Vertical louver	
7	1541368	Holder center	
8	1550291	Vertical louver	
9	1550300	Vertical louver	
10	1541363	Louver	
11	1222824	Plug	
12	1541633	Cross flow fan assy	
13	1223738	Bearing	
14	1465670	Baffle	
15	1838915	Evaporator	
16	1541382	Front panel	
17	1826559	Ornamental part	
18	1541388	Ornamental part	
19	1824935	Display assembly	
20	4151757	Intake grille	
21	1541389	Ornamental part	
22	1837499	Thermistor pipe	
23	1896665	Thermistor pipe	
24	1561456	Motor fan	
25	1541374	Cover motor	
26	1541375	Guard motor	
27	1541361	Baffle	
28	1470426	Drain hose	
29	1819726	Step motor	
30	1541500	Electric box cover	
31	1870720	Electric box	
32	1989042	Controller PCB	
33	1541507	Cover wire	
34	1837043	Cover wire	
35	1852126	Terminal	
36	1840141	Clamp cord	
37	1541379	Cover display	
38	4151687	Remote control	
	1541387	Air filter	




INDOOR UNIT WHP24WMA21S

No.	Part number	Description	
1	1907022	Bracket wall	
2	1954365	Base assembly	
3	1260311	Step motor	
4	1541366	Holder center	
5	1541373	Guard motor	
6	1541456	Vertical louver	
7	1541368	Holder center	
8	1550291	Vertical louver	
9	1550300	Vertical louver	
10	1541363	Louver	
11	1222824	Plug	
12	1541633	Cross flow fan assy	
13	1223738	Bearing	
14	1465670	Baffle	
15	1556041	Evaporator	
16	1541382	Front panel	
17	1826559	Ornamental part	
18	1541388	Ornamental part	
19	1824935	Display assembly	
20	4151757	Intake grille	
21	1541389	Ornamental part	
22	1837499	Thermistor pipe	
23	1896665	Thermistor pipe	
24	1561456	Motor fan	
25	1541374	Cover motor	
26	1541375	Guard motor	
27	1541361	Baffle	
28	1470426	Drain hose	
29	1819726	Step motor	
30	1541500	Electric box cover	
31	1870720	Electric box	
32	1997858	Controller PCB	
33	1541507	Cover wire	
34	1837043	Cover wire	
35	1852126	Terminal	
36	1840141	Clamp cord	
37	1541379	Cover display	
38	4151687	Remote control	
	1541387	Air filter	




OUTDOOR UNIT WHP09SZA21S

No.	Part number	Description	
1	2135537	Front panel w/ grille	
2	1405123	Propeller fan blade	
3	1820938	Fan motor	
4	1824869	Motor bracket	
5	1824871	Mounting plate	
6	1824865	Top panel	
7	1824902	Protective net back	
7	1824903	Protective net left	
8	1854202	Condenser assembly	
9	1854218	Base assembly	
10	1858994	Clapboard part	
11	1829624	Choke coil	
12	1854176	Valve 4 way TA	
13	1258654	Valve 4 way	
14	1511783	Solenoid	
15	1838380	Compressor	
16	1822371	Compressor wire	
17	1824870	Bracket valve	
18	1838379	Capillary assembly	
19	1258653	Valve 2 way 1/4	
20	1407169	Valve 3 way 3/8	
21	1855206	Cabinet right	
22	1854033	Bracket conduit	
23	1854034	Plate cover	
24	1894523	Electric box	
25	1843011	Connecting board	
26	1854383	Wire terminal board	
27	1985606	Inverter control PCB	
28	1894526	Cover wire	
29	1472663	Thermistor discharge	
30	1472664	Thermistor pipe	
31	1831029	Thermistor outdoor	
	1854709	Tube electric heater	




OUTDOOR UNIT WHP12SZA21S

No.	Part number	Description	
1	2138572	Front panel w/ grille	
2	1556766	Propeller fan blade	
3	1457759	DC motor	
4	1849292	Motor bracket	
5	1846086	Mounting plate	
6	1846082	Top panel	
7	1854579	Protective net back	
7	1854580	Protective net left	
8	1851339	Condenser assembly	
9	1851356	Base assembly	
10	1847982	Separate wall	
11	1829624	Choke coil	
12	1923524	Valve 4 way TA	
13	1511783	Solenoid	
14	1258654	Valve 4 way	
15	1821191	Compressor	
16	1822371	Compressor wire	
17	1854557	Capillary assembly	
18	1844583	Valve 2 way 1/4	
19	1335015	Valve 3 way 3/8	
20	1846084	Cabinet right	
21	1854040	Bracket conduit	
22	1854034	Plate cover	
23	1937153	Connecting board	
24	1852124	Wire terminal board	
25	1951957	Electric box	
26	1985663	Inverter control PCB	
27	1894526	Cover wire	
28	1472663	Thermistor discharge	
29	1511780	Thermistor pipe	
30	1831029	Thermistor outdoor	
31	1546721	Sensor mount plate	
32	1854766	Tube electric heater	



OUTDOOR UNIT WHP18SZA21S

No.	Part number	Description	
1	2138571	Front panel w/ grille	
2	1841783	Propeller fan blade	
3	1859837	DC motor	
4	1841953	Motor bracket	
5	1841772	Mounting plate	
6	1841779	Top panel	
7	1854661	Protective net left	
7	1871792	Protective net back	
8	1854747	Condenser assembly	
9	1841349	Base assembly	
10	1841986	Separate wall	
11	1205797	Choke coil	
12	1888252	Valve 4 way TA	
13	1511783	Solenoid	
14	1408045	Valve 4 way	
15	1850482	Compressor	
16	1847142	Wire compressor	
17	1854774	Capillary assembly	
18	1844583	Valve 2 way 1/4	
19	1844499	Valve 3 way 1/2	
20	1841776	Cabinet right	
21	1854040	Bracket conduit	
22	1854034	Plate cover	
23	1842392	Connecting board	
24	1852124	Wire terminal board	
25	1841985	Electric box	
26	1854367	Inverter control PCB	
27	1546706	Electric box cover	
28	1511780	Thermistor pipe	
29	1511782	Thermistor pipe	
30	1831029	Thermistor outdoor	
31	1546721	Sensor mount plate	
	1854710	Tube electric heater	



OUTDOOR UNIT WHP24SZA21S

No.	Part number	Description	
1	1542623	Front panel w/ grille	
2	1542217	Propeller fan blade	
3	1561964	Fan motor	
4	1561919	Motor bracket	
5	1878885	Top panel	
6	1819106	Protective net back	
7	1854549	Condenser assembly	
8	1814292	Base assembly	
9	1534867	Bracket valve	
10	1205797	Choke coil	
11	2017922	Valve 4 way	
12	1830018	Compressor	
13	1847142	Wire compressor	
14	1867906	EEV assembly	
15	1536052	Valve 2 way 3/8	
16	1456114	Valve 3 way 5/8	
17	1866429	Cabinet right	
	2006156	Inverter control PCB	
	1852124	Wire terminal board	
	1822633	Thermistor pipe	
	1822634	Thermistor discharge	
	1852304	Thermistor outdoor	
	1863482	Clapboard part	
	1865713	Cover display	
	1854767	Tube electric heater	

Accessories

Indoor unit

Part name	Q'ty	Part name	Q'ty
Remote controller instructions	1	1 Drain joint rubber seal	
Use and installation instructions	1	Flare nuts	4
Remote controller	1	Bag of wall anchors and screws	1
Remote controller holder	1	Screw for installations	5
AAA battery	2	Screw cover	09/12 model: 1
AAA ballery			18/24 model: 3
Foam insulation	09-18 model: 1	Warranty Card	1
Foam insulation	24 mode: 2	Warranty Card	ı
Drain joint	1		

Outdoor unit

Part name	Q'ty	Part name	Q'ty
Use and installation instructions	1	Power wire	1
Bottom rubber for outdoor unit	4		