

ZR57K3E-TF5

HFC, R-407C, 60 Hz, 3 - Phase, 200/230 V , [Also Available with Variable Frequency Drives](#)

Air Conditioning

Production Status: This compressor and/or application of this compressor is not available to U.S. OEM customers. A field replacement is currently available through a U.S. Copeland Wholesaler. Please check with your local Copeland Representative for international availability.

Performance			Mechanical	
Evaporator Temp. (°F)	45.00	45	Displacement (in^3/Rev):	4.71
Condensing Temp. (°F)	130.00	100	Displacement (ft^3/Hr):	
Return Gas Temp. (°F)	65.00	65	Overall Length (in):	9.70
Liquid Temp. (°F)	115.00	85	Overall Width (in):	9.80
Capacity (BTU/hr)	54900	66200	Overall Height (in):	17.20
Power (W):	5120	3390	Mounting Length (in):	7.50
Current (Amps):	15.3	11.4	Mounting Width (in):	7.50
EER(BTU/Wh):	10.75	19.55	Mounting Height (in):	18.00
Mass Flow (lbs/hr):	793	817	Suction Size (in),Type:	7 / 8 Stub
Sound Data @			Discharge Size (in),Type:	1 / 2 Stub
Sound Power (dBA):	74 Avg	79 Max	Initial Oil Charge (oz):	66
Vibration mils(peak-peak):	2.0 Avg	3.0 Max	Oil Recharge (oz):	62
Record Date:	2014-08-07		Oil Type:	3MA
			Net Weight (lbs):	85.0
			Internal Free Volume (in^3):	257.0
			*Overall compressor height on Copeland Brand Product's specified mounting grommets.	

Electrical		Capacitors				
LRA High* (Amps):	123	Type	Part No	Low MFD	High MFD	Volts User Description
LRA Low*(Amps):		No data available in table				
LRA Half Winding (Amps):						
MCC (Amps):	27					
Max Operating Current (Amps):	18.00					
RLA, MCC/1.4(use for contactor selection)(Amps):	19.3					
RLA, MCC/1.56(use for breaker & wire size selection)(Amps):	17.3					
RPM:	3500					
Box IP :	21					
UL File No:	SA2337-19930726					
UL File Date:	1993-07-26					

*Low and High refer to the low and high nominal voltage ranges for which the motor is approved.

Alternate Applications				
Refrigerant	Voltage	Phase	Frequency	Application
R-22 HCFC	200/220	3	50	Air Conditioning
R-22 HCFC	200/230	3	60	Air Conditioning
R-407C HFC	200/220	3	50	Air Conditioning