ZR61K3E-TFD

HFC, R-407C, 60 Hz, 3 - Phase, 460 V <u>, Also Available with Variable Frequency Drives</u> Air Conditioning

Production Status: This compressor and/or application of this compressor is not available to U.S. OEM customers. A field replacement is currently available through a U.S. Copeland Wholesaler. Please check with your local Copeland Representative for international availability.

Performance			Mechanical		
Evaporator Temp. (°F)	45.00	45	Displacement (in^3/Rev):	5.04	
Condensing Temp. (°F)	130.00	100	Displacement (ft^3/Hr):		
Return Gas Temp. (°F)	65.00	65	Overall Length (in):	9.70	
Liquid Temp. (°F)	115.00	85	Overall Width (in):	9.70	
Capacity (BTU/hr)	58700	70800	Overall Height (in):	17.20	
Power (W):	5470	3620	Mounting Length (in):	7.50	
Current (Amps):	8.2	6.1	Mounting Width (in):	7.50	
EER(BTU/Wh):	10.75	19.55	Mounting Height (in):	18.00	
Mass Flow (Ibs/hr):	848	874	Suction Size (in),Type:	7 / 8 Stub	
Sound Data @			Discharge Size (in),Type:	1 / 2 Stub	
Sound Power (dBA):	74 Avg	79 Max	Initial Oil Charge (oz):	66	
Vibration mils(peak-peak):	2.0 Avg	3.0 Max	Oil Recharge (oz):	62	
Record Date:	2014-08-07		Oil Type:	ЗМА	
			Net Weight (Ibs):	84.0	
			Internal Free Volume (in^3):	257.0	
			*Overall compressor height on Copeland Brand Pro mounting grommets.	oduct's specified	
Electrical			Capacitors		
LRA High* (Amps):		62	Type Part No Low MFD High MFD Volts Us	ser Description	
LRA Low*(Amps):			No data available in table		
LRA Half Winding (Amps):					
MCC (Amps):		12.8			
Max Operating Current (Amps):		9.60			
RLA, MCC/1.4(use for contactor selection)(Amps):		9.1			
RLA, MCC/1.56(use for breaker & wire size selection)(Amps):		8.2			
RPM:		3500			
Box IP :		21			
UL File No:		SA2337- 19930726			
UL File Date:		1993-07- 26			
*Low and High refer to the low and high which the motor is approved.	nominal voltage	ranges for			

Alternate Applications

Refrigerant	Voltage	Phase	Frequency	Application
R-22 HCFC	460	3	60	Air Conditioning
R-22 HCFC	380/420	3	50	Air Conditioning
R-407C HFC	380/420	3	50	Air Conditioning